

## Testprotokoll Wago 750-8215

Undersentral nr : =563-OU001

Dato: 24/04/2024

Ref: Kevin S.

System nr. :	=100 -	Vannbehandling
	=200 -	Miljø og inneklima
	=300 -	Automasjon og overvåkning
	=563 -	Lokal automatisering

### WAGO 750-557 (4-channel Analogue Output Module)

Kanal	Description	I/O	Type	Status	Kommentar
1	Output Channel 1	Output	Analogue	Pass	OK
2	Output Channel 2	Output	Analogue	Pass	OK
3	Output Channel 3	Output	Analogue	Pass	OK
4	Output Channel 4	Output	Analogue	Pass	OK

### WAGO 750-530-1 (8-channel Digital Output Module)

Kanal	Description	I/O	Type	Status	Kommentar
1	Output Channel 1	Output	Digital	Pass	OK
2	Output Channel 2	Output	Digital	Pass	OK
3	Output Channel 3	Output	Digital	Pass	OK
4	Output Channel 4	Output	Digital	Pass	OK
5	Output Channel 5	Output	Digital	Pass	OK
6	Output Channel 6	Output	Digital	Pass	OK
7	Output Channel 7	Output	Digital	Pass	OK
8	Output Channel 8	Output	Digital	Pass	OK

**WAGO 750-530-2 (8-channel Digital Output Module)**

Kanal	Description	I/O	Type	Status	Kommentar
1	Output Channel 1	Output	Digital	Pass	OK
2	Output Channel 2	Output	Digital	Pass	OK
3	Output Channel 3	Output	Digital	Pass	OK
4	Output Channel 4	Output	Digital	Pass	OK
5	Output Channel 5	Output	Digital	Pass	OK
6	Output Channel 6	Output	Digital	Pass	OK
7	Output Channel 7	Output	Digital	Pass	OK
8	Output Channel 8	Output	Digital	Pass	OK

**WAGO 750-430-1 (8-channel Digital Input Module)**

Kanal	Description	I/O	Type	Status	Kommentar
1	Input Channel 1	Input	Digital	Pass	OK
2	Input Channel 2	Input	Digital	Pass	OK
3	Input Channel 3	Input	Digital	Pass	OK
4	Input Channel 4	Input	Digital	Pass	OK
5	Input Channel 5	Input	Digital	Pass	OK
6	Input Channel 6	Input	Digital	Pass	OK
7	Input Channel 7	Input	Digital	Pass	OK
8	Input Channel 8	Input	Digital	Pass	OK

**WAGO 750-430-2 (8-channel Digital Input Module)**

Kanal	Description	I/O	Type	Status	Kommentar
1	Input Channel 1	Input	Digital	Pass	OK
2	Input Channel 2	Input	Digital	Pass	OK
3	Input Channel 3	Input	Digital	Pass	OK
4	Input Channel 4	Input	Digital	Pass	OK
5	Input Channel 5	Input	Digital	Pass	OK
6	Input Channel 6	Input	Digital	Pass	OK
7	Input Channel 7	Input	Digital	Pass	OK
8	Input Channel 8	Input	Digital	Pass	OK

**WAGO 750-554 (2-channel Analogue Output Module)**

Kanal	Description	I/O	Type	Status	Kommentar
1	Output Channel 1	Output	Analogue	Pass	OK
2	Output Channel 2	Output	Analogue	Pass	OK

**WAGO 750-466 (2-channel Analogue Input Module)**

Kanal	Description	I/O	Type	Status	Kommentar
1	Input Channel 1	Input	Analogue	Pass	OK
2	Input Channel 2	Input	Analogue	Pass	OK

**WAGO 750-652 (RS232/RS485 Communication Module)**

Function	Description	I/O	Type	Status	Kommentar
Kom.	Kommunikasjon for RS485 komponenter. Modbus RTU.	---	Kom.	Pass	KommunkasjonOK

**Kvittert:**

Navn: <u>Kevin Silbernagel / Peter Lingås</u>	Signatur: <u>Kevin.S / Peter.L</u>	Dato: 13/04/2024 _____
---	------------------------------------	------------------------